



RAHUL ENGINEERS LABORATORY PVT. LTD.

A Trusted Independent Third Party Laboratory
(A Govt. of INDIA Regd. MSME Unit)



ISO/IEC 17025 : 2017 Accredited & ISO 9001 : 2015 Certified



MSME - UDYAM-RJ-33-0079872 | CIN - U20224RJ2024PTC094505 | GSTIN - 08AANCR6414K1ZX | PAN - AANCR6414K

FACILITIES : Aggregate (Coarse & Fine,) Bituminous Mx, Bitumen, Bricks, Concrete, Paver Block, Metal & Alloys, Stone, Marble, Granite, Slab, Soil, Concrete NDT (Rebound Hammer & UPV), Cement, Plaster of Paris, Bauxite, Aluminum, Red Ochre, Iron Ore, Diatomaceous Earth, Siliceous Earth, Water, Soapstone, Talc, Feldspar, Limestone, Dolomite, Calcite, Magnesite, Quartz, Silica Sand

5-A, Chitrakut Nagar, Bhuwana By-pass Road, Udaipur (Raj.) PIN 313 001, INDIA

☎ : +91 6350324167, +91 8107343935, ✉ : lab@rahulengineers.com, rahul.labudr@gmail.com, 🌐 : www.rahulengineers.co



Doc.No.-RELPL/7.8/Chem/TR/F-2/REV.00 Dated. 01.06.2024

Report No: - RELPL-Chem. /251144-1
ULR No-91TL1152500002987P

Date: - 13.11.2025

TEST REPORT (Water)

1	Name of Customer	:	VIDYA BHAWAN PUBLIC SCHOOL Dewali, Udaipur (Raj.)
2	Customer Contact No.	:	7878245235 , (vbpsudr@gmail.com)
3	Customer Reference No.	:	VBPS/2025-26/193, Dated : - 07.11.25
4	Type of Sample	:	Water
5	Sample Identification	:	RO water
6	Date & Mode of Receipt of Sample	:	10.11.25, Sample Collected by RELPL Team.
7	RELPL Job No.	:	RELPL-251144-1
8	Name of Work	:	Testing of Water For Drinking Purpose.
9	Location	:
10	Date of Sampling	:	10.11.25
11	Date of Testing	:	11.11.25 to 13.11.25



Kiran
Vidya Bhawan Public School
Dr. Mohan Singh Mehta Marg
Fatehpura, Dewali Road
UDAIPUR (Raj.) 313004

Principal
Principal
Vidya Bhawan Public School
Udaipur (Raj.)





RAHUL ENGINEERS LABORATORY PVT. LTD.

A Trusted Independent Third Party Laboratory
(A Govt. of INDIA Regd. MSME Unit)



ISO/IEC 17025 : 2017 Accredited & ISO 9001 : 2015 Certified



MSME - UDYAM-RJ-33-0079872 | CIN - U20224RJ2024PTC094505 | GSTIN - 08AANCR6414K1ZX | PAN - AANCR6414K

FACILITIES : Aggregate (Coarse & Fine,) Bituminous Mix, Bitumen, Bricks, Concrete, Paver Block, Metal & Alloys, Stone, Marble, Granite, Slab, Soil, Concrete NDT (Rebound Hammer & UPV), Cement, Plaster of Paris, Bauxite, Aluminum, Red Ochre, Iron Ore, Diatomaceous Earth, Siliceous Earth, Water, Soapstone, Talc, Feldspar, Limestone, Dolomite, Calcite, Magnesite, Quartz, Silica Sand

5-A, Chitrakut Nagar, Bhuwana By-pass Road, Udaipur (Raj.) PIN 313 001, INDIA

☎ : +91 6350324167, +91 8107343935, 📧 : lab@rahulengineers.com, rahul.labudr@gmail.com, 🌐 : www.rahulengineers.cc

Doc.No.-RELPL/7.8/Chem/TR/F-2/REV.00 Dated 01.06.2024

Report No: - RELPL-Chem. /251144-1

Date: - 13.11.2025

ULR No-91TL1152500002987P

Test Results:-

S. No.	Parameters	Results	Specification for Drinking Water as per IS:10500: 2012(RA-2023)		Test Method reference of IS: 3025
			Requirement (Acceptable Limit) (max.)	Permissible Limit in the Absence of Alternate Source (max.)	
1	pH at 25°C	7.3	6.5 to 8.5	No relaxation	(Part-11):1983 (RA-2017)
2	Total Dissolved Solids (mg/l)	632.0	500	2000	(Part-16) : 2023
3	Total Hardness as CaCO ₃ (mg/l)	374.0	200	600	(Part-21):2009 (RA-2019)
4	Calcium as Ca(mg/l)	120.0	75	200	(Part-40):1991 (RA-2019)
5	Magnesium as Mg (mg/l)	17.76	30	100	(Part-46):1994 (RA-2019)
6	Chlorides as Cl (mg/l)	123.0	250	1000	(Part-32):1988 (RA-2019)
7	Sulphate as SO ₄ (mg/l)	72.58	200	400	(Part-24/Sec 1) 2022
8	Alkalinity as CaCO ₃ (mg/l)	330.0	200	600	(Part-23) : 2023
9	** Nitrate as NO ₃ (mg/l)	16.0	45	No relaxation	(Part-34) :1988RA-2019
10	**Fluoride as F (mg/l)	0.10	1.0	1.5	(Part-60):2008 (RA-2019)
11	**Turbidity (NTU)	< 1.0	1	5	(Part-10) : 2023
12	** Most Probable No. Of Coliform per 100ml of water (MPN)	Zero	Shall not be detectable in any 100ml Sample		IS 1622 :1981 (RA-2019)

Remarks: -

- The parameters in Bold are not in Acceptable Limit but within Permissible Limit in the absence of alternate source.
- The parameters in Bold with * are not in Permissible Limit.

Kiran Kumar
Manager
Vidya Bhawan Public School
Dr. Mohan Singh Mehta Marg
Fatehpura, Dewali Road
UDAIPUR (Raj.) 313004

[Signature]
Principal
Vidya Bhawan Public School
Udaipur (Raj.)
Page 2 of 3



[Signature]



RAHUL ENGINEERS LABORATORY PVT. LTD.

A Trusted Independent Third Party Laboratory
(A Govt. of INDIA Regd. MSME Unit)



ISO/IEC 17025 : 2017 Accredited & ISO 9001 : 2015 Certified



MSME - UDYAM-RJ-33-0079872 | CIN - U20224RJ2024PTC094505 | GSTIN - 08AANCR6414K1ZX | PAN - AANCR6414K

FACILITIES : Aggregate (Coarse & Fine,) Bituminous Mix, Bitumen, Bricks, Concrete, Paver Block, Metal & Alloys, Stone, Marble, Granite, Slab, Soil, Concrete NDT (Rebound Hammer & UPV), Cement, Plaster of Paris, Bauxite, Aluminum, Red Ochre, Iron Ore, Diatomaceous Earth, Siliceous Earth, Water, Soapstone, Talc, Feldspar, Limestone, Dolomite, Calcite, Magnesite, Quartz, Silica Sand

5-A, Chitrakut Nagar, Bhuwana By-pass Road, Udaipur (Raj.) PIN 313 001, INDIA

☎ : +91 6350324167, +91 8107343935, ✉ : lab@rahulengineers.com, rahul.labudr@gmail.com, 🌐 : www.rahulengineers.co

Doc.No.-RELPL/7.8/Chem/TR/F-2/REV.00 Dated. 01.06.2024

Report No: - RELPL-Chem. /251144-1
ULR No-91TL1152500002987P

Date: - 13.11.2025



Sample Photograph

Tested By:

Priyanka
(Priyanka Vaishnav)
Chemist



Authorised By:

S.C. Parikh
(S.C. Parikh)
Tech. Manager (Chem.).

Note: -

1. Test report is authentic only if contain hallmark and seal.
2. * *Non Accredited value.
3. The test results refer only to the samples received in the Laboratory.
4. Sample Collected by RELPL Team and Information Regarding to sample is provided by Customer.
5. Rahul Engineers Laboratory shall not in any way be involved in any action following the interpretation of test results.
6. Any discrepancy in test results should be reported within 15 days.
7. This report shall not be reproduced except in full without written approval from Rahul Engineers Laboratory Pvt Ltd.
8. Subject to Udaipur Jurisdiction only.

End of Report

Manoj Singh
Manager
Vidya Bhawan Public School
Dr. Mohan Singh Mehta Marg
Fatehpura, Dewali Road
UDAIPUR (Raj.) 313004

Page 3 of 3

Manoj Singh
Principal
Vidya Bhawan Public School
Udaipur (Raj.)